



# Sophisticated Industrial Materials Analytic Labs. Pvt. Ltd.

AN ISO 9001 CERTIFIED, MoEF & BIS RECOGNISED GOVT. APPROVED TEST HOUSE

## TEST REPORT

5.10 F-01

PARTY CODE : A/PB/142

REPORT NO. : SS07/002015

SUB. BY : AGI INFRA LTD.  
66 FT. ROAD. VILLAGE PHOLRIWAL, JALANDHAR

SAMPLE : EFFLUENT WATER  
(STP-OUTLET)

Ref No. : NS

DT Recd : 06-07-2015


### RESULTS OF ANALYSIS Reference : EP Act Standard

Description	: One Effluent water sample from Outlet of STP was collected by us on 04/07/15		
PARAMETERS	Results	Limit (Max.)	Protocols
01. pH	: 7.54	5.5 to 9.0	IS:3025 (P-11)
02. Total Suspended Solids	: <5 mg/L	100 mg/L	IS:3025 (P-17)
03. Total Dissolved Solids	: 618 mg/L	2100 mg/L	IS:3025 (P-16)
04. Chemical Oxygen Demand	: 114 mg/L	250 mg/L	IS:3025 (P-58)
05. Biochemical Oxygen Demand (for 3 days at 27 Deg. C)	: 24 mg/L	30 mg/L	IS:3025 (P-44)
06. Oil & Grease	: <3 mg/L	10 mg/L	IS:3025 (P-39)
07. Total Coliform	: 63/100 ml	--	IS:1622

Date of performance : 06/07/15 to 11/07/15

### SAMPLE COLLECTED BY US

  
PERSON IN CHARGE

  
ANALYST

DATE 11-07-2015

Page 1 of 1 shiv / suk

- NOTE: 1. Results listed refer only to the tested sample & applicable parameters. Endorsement of products is neither inferred nor implied.  
2. Liability of laboratory is limited to the invoiced amount only. Any dispute arising out of this report shall be subject to Delhi jurisdiction only.  
3. The Report shall not be reproduced either in full or part without the written approval of laboratory.  
4. Sample shall be disposed off after issue of Test Report unless specified.

**NOT VALID FOR CONSENT PURPOSE**